

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4025-1513:100

Page 1 of 1

CATEGORY: Fusible Links

LISTEE: PHL Inc., 3859 Old Easton Highway, Doylestown, PA 18901
Contact: Richard McNutt (215) 345-8405

DESIGN Fusible link assembly, "The McCabe Link" Models 5712, 5720, E5720, 5730, E5730, 5734 and 5740. Unit consists of a bimetallic thermal actuator mounted on a metal frame. Model 5712 may be stainless steel, nickel or zinc-plated. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:	MODEL	DIRECTION	LOAD RATING		TEMP. (°F)
			Min.	Max.	
	5712	Vertical	1	10	165
	5720, E5720	Vertical	1	25	160 or 171
	5720, E5720	Horizontal	1	5	160 or 171
	5730, E5730	Vertical	1	25	205 or 220
	5730, E5730	Horizontal	1	8	205 or 220
	5734	Vertical	1	25	261 or 280
	5734	Horizontal	1	8	261 or 280
	5740	Vertical	1	15	357 or 383
	5740	Horizontal	1	5	357 or 383

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, temperature rating and UL label.

APPROVAL: Listed as fusible link assemblies for use with separately listed fire dampers. Units are intended for use on doors measuring up to 4' wide and 8' high.

07-14-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**